

Bogota High School S.O.G. - Adopted November 25, 2019

Apparatus Allocations:

- **Ladder-** should go up Kovar Street into the driveway and position in front of the building at the end of the teacher's parking lot.
- **1st Due Engine-** Stand by at the hydrant on Kovar Street and Palisade Ave. Crews can walk up if needed for the investigation.
- **2nd Due Engine-** Stage at East Broad Street and Palisade Ave at the hydrant. Crews can walk up if needed for the investigation.
- **3rd Due Engine-** Stage at Main Street and Palisade Ave, await orders.

Any apparatus can be redirected at the discretion of the incident commander.

Personnel Allocations:

- 1st arriving Officer and two (2) firefighters from the first responding engine and ladder should verify the location of the alarm and investigate.
- At this point, the incident command should take over from the S.O.G.

Utilities:

- Main gas shut off exterior Alpha side A/B corner.
- Main Electric Shut off in boiler room next to the alarm panel.
- Alarm panel located in the boiler room.
- Main water shut off basement alpha side inside the special services room in the center of the building.
- Three boilers, shutoffs are on the side of each boiler.
- Gas shut off for cafeteria located in the middle of the kitchen.

Special Notes:

- Pre-connected hose lines should not be used.
- Master key for all doors in Knox box at B side.
- Aerial access from Gray Street if needed.
- There is a hydrant in the middle of Highwood Street in Teaneck, the rear of the building.
- Light Bar Truss Roof rear section of the building.
- Pad Mount Transformer on the exterior Alpha side (primary voltage).
- Freight Elevator- Shut off in Librarian's office.
- Numerous crawlspaces in building use caution.
- Roof access from the custodial closet second floor D side.
- Hazardous Materials on Alpha side second floor. Closet in the classroom at A/D corner.
- Ladder access in rear. Highwood Street limited ladder access, the ladder should be in the block before the engine.
- Dum Waiter power shut off for the cafeteria in the kitchen B side by kitchen stairs.
- Access Stairs to the second floor in Music Room.

- Cupola/Roof access on A side through the custodial closet second floor.
- The roof over auditorium is flat and lower than the rest of the roof. Need a ground ladder to access.
- Short knee wall balcony in the auditorium on the second floor.
- Be aware the gym may have partitions.
- Recommended to have PD close Palisade Avenue in both directions.